Sanitized Copy Approved for Release 2011/04/14 : CIA-RDP78B04747A003100030023-0

SECRET

8 October 1963

MEMORANDUM FOR: Assistant for Administration

ATTENTION [redacted] 25X1

THROUGH : Assistant for Plans & Development

SUBJECT : Environmental Requirements for Room 4N426A

1. In order that the Multiple Image Correlator can be used in Room 4N426A it will be necessary to have effective temperature regulation. The correlator and its associated instrumentation will greatly increase the temperature in this room if there is no air conditioning. Temperature should be about 72° ± 2° F. Power requirements are for a 115 volt AC, 60 cycle, single phase circuit; subdued lighting should also be available.

2. The instrument is to be delivered in nine (9) weeks and will remain in Room 4N426A for approximately two (2) additional weeks for demonstration and evaluation procedures.

25X1

[redacted]

Development Branch, P&DS

Distribution:
Orig & 1 - Addressee
2 - P&DS/DB

SECRET

SECRET
Excluded from automatic downgrading and declassification

Sanitized Copy Approved for Release 2011/04/14 : CIA-RDP78B04747A003100030023-0